



# GRANITE STATE ANALYTICAL SERVICES, LLC.

2541 White Mountain Highway, Unit 7, North Conway, New Hampshire 03860  
Phone: (603) 447-4826 website: www.granitestateanalytical.com

DATE PRINTED: 05/09/2019

SYSTEM NAME: Kennett Middle School  
SYSTEM TOWN: Conway  
SAMPLE CATEGORY: Repeat Sample  
SAMPLING AGENT: MacDonald, Holly  
SAMPLE AGENT #: 603-447-4826  
RECEIPT TEMP: ON ICE 8° CELSIUS

## LEAD RESULTS

LAB ID#: 1015

COMPLIANCE PERIOD: CHEMICAL RESULTS FOR THE QUARTER 2019

EPA ID #: Sch-27010  
WATER SYSTEM TYPE: mg/L  
TEST UNITS: EPA 200.8  
METHOD: 0.015 mg/L  
MCL: 0.001 mg/L  
MDL (RL):  
DATE & TIME RECEIVED: 05/03/2019 9:12AM  
ANALYST: JLR-NH

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

DATE/TIME COLLECTED	LABORATORY SAMPLE ID#	CLIENT JOB #	LEAD *	Pass /Fail	DATE ANALYZED
05/03/2019 8:00AM	1905-00389-001		<0.001	✓	05/08/19
05/03/2019 8:01AM	1905-00389-002		<0.001	✓	05/08/19
05/03/2019 8:03AM	1905-00389-003		0.0013	✓	05/08/19

001 Water Fountain across from A-20 Left  
002 Water Fountain across from A-20 Right  
012 Football Locker Rm

The results presented in this report relate to the samples listed above in the condition in which they were received.  
RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

\* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.  
Laboratory Director